



Bid/Proposal No. P20/10015 - Comprehensive, Integrated Energy Management Program

Clarification/Correction to Question 9 of Questions and Answers

9. Question: What type of building automation system does the campus utilize? What percent of floorspace is covered by this system?

Answer: The College currently uses 3 different control systems (iNET, Alerton & Delta). The College is currently converting all controls to Delta controls. No other automation controls will be considered. 100% of the space provided in answer 1 is controlled by the building automation systems.

Correction:

Answer to Question 9 should read:

**The College currently uses 3 different control systems (iNET, Alerto & Delta)
100% of the space provided in answer 1 is controlled by the building automation systems.**